Building Services, Room 201

City-County Building

300 West Ash · P.O. Box 736

Salina, Kansas 67402-0736

City of

Salina

TELEPHONE · (785) 309-5715

FAX · (785) 309-5713

TDD · (785) 309-5747

WEBSITE · www.salina-ks.gov

Residential Interior Stairs- Rough Inspection   DRAFT

| Address: | | Contractor: | | Permit # | |

The following checklist is not all-inclusive. Other code related requirements may be included in this inspection

OK Yes No n/a ☐ ☐ ☐	Verify minimum 36" stairway width. IRC sec R311.5.1	OK Yes No n/a ☐ ☐ ☐	Verify adequacy of stair framing.
OK Yes No n/a ☐ ☐ ☐	Verify maximum 8" riser height and minimum 9" tread width measured from nose to nose. IRC sec R311.5.3	OK Yes No n/a ☐ ☐ ☐	Verify that treads are level. IRC sec R311.5.5
OK Yes No n/a ☐ ☐ ☐	Verify maximum 3/8" differential in riser heights or tread widths. IRC sec R311.5.3	OK Yes No n/a ☐ ☐ ☐	Verify minimum tread widths for winders. IRC sec R311.5.3
OK Yes No n/a ☐ ☐ ☐	Verify that closed-riser nosings have overhangs between ¾" and 1¼". IRC sec R311.5.3.3	OK Yes No n/a ☐ ☐ ☐	Verify required headroom. IRC sec R311.5.2
OK Yes No n/a ☐ ☐ ☐	Verify that provisions have been made for a continuous handrail on at least one side of the stairs. IRC sec R311.5.6	OK Yes No n/a ☐ ☐ ☐	Verify that landings at the top and bottom of the flight of stairs are minimum 36" in length. Note door swing at the top of the stairs. IRC sec R311.5.4

Notes:

Date		Inspector	